

Answer Key

Lesson # 9: Storage (*Fire Safety*)

Correct Answers for Part 2:

- 1.) B
- 2.) A
- 3.) D
- 4.) **1910.39(c)(2)**: Procedures to control accumulations of flammable and combustible waste materials;

NFPA: National Fire Protection Association

1910.159(c)(10): Sprinkler spacing. The employer shall assure that sprinklers are spaced to provide a maximum protection area per sprinkler, a minimum of interference to the discharge pattern by building or structural members or building contents and suitable sensitivity to possible fire hazards. The minimum vertical clearance between sprinklers and material below shall be 18 inches.